

# mySmart PDS

## Presence Detector



### Description

The PDS presence detection switch replaces a standard single gang light switch. It detects movement using a PIR sensor and turns the lights on, (either incandescent and fluorescent loads). An internal light sensor is provided for additional energy saving. When an area is occupied lighting is only switched on when the level of natural light is below a preset level.


When an area is no longer occupied the lights will switch off after an adjustable time out period.

The PDS-OV comes with a manual override facility for turning lights on and off by simply pressing the lamp symbol in the bottom right hand corner of the front plate.

If the lights are on, using the override will turn the lights off permanently until the override is pressed again.

If the lights are off (because of the ambient light), use the override to turn the lights on. The lights will remain on until the occupancy period is over.

## Dimensions



### LIGHTS DO NOT COME ON

For the PSD-OV model only, press the lamp symbol to ensure that the controller has not been switched off manually.

Check to see if the live supply to the circuit is good. Strap across the *L* and *LIVE OUT* terminal to turn the load on. If the supply and wiring are good, check the LUX level setting. Increase the LUX level setting to allow the controller to turn on at higher ambient natural light level. If the load still fails to turn on follow step 5 of the installation instructions to recharge the internal battery.


### LIGHTS DO NOT GO OFF

Ensure that the area is left unoccupied for a greater time period than the time out period set using the switch. Make sure that the sensor is not adjacent to circulating air, heaters or lamps.

### LIGHTS FLICKER

Ensure that there are sufficient power factor correction capacitors fitted.

## Detection Area



## Specification

### LOAD

10 Amp incandescent lighting  
 6 Amp fluorescent lighting  
 3 Amp compact fluorescent lighting  
 3 Amp low energy lighting  
 3 Amp low voltage lighting (switch primary of transformer)  
 Fluorescent lighting (max 6 fittings recommended)  
 Fluorescent and compact fluorescent fittings with "switch start" ballasts - 6 ballasts maximum.  
 Power factor correction capacitors must be fitted. Most fluorescent fittings have power factor correction capacitors fitted. If they are not present the unit may fail the installation procedure, in which case fit one capacitor per circuit with a minimum value of 1 $\mu$ F for every PDS or PDS-OV installed. Note that it is not necessary to fit a capacitor on every fitting. For fluorescent lighting total power factor correction capacitance must not exceed 40 $\mu$ F.

*Not suitable for switching contactors*

*Not suitable for SON lighting*

*Not suitable for heating or ventilation loads.*

<b>SUPPLY VOLTAGE</b>	220-240 Volts AC 50 Hz
<b>TIME OUT PERIOD</b>	Adjustable 5 minutes to 60 minutes by DIP switch.
<b>LIGHT LEVEL</b>	Adjustable by thumbwheel light to dark.
<b>FIXING METHOD</b>	Surface fixing 25mm deep plastic surface mount moulded box. Flush fixing 15mm steel wall box or 32mm deep cavity wall box.
<b>TERMINAL CAPACITY</b>	1.5mm <sup>2</sup>
<b>MATERIAL</b>	Flame retardant ABS
<b>TYPE</b>	Class 2
<b>TEMPERATURE</b>	-10°C to 35°C
<b>CONFORMITY</b>	EMC-89/336/EECLVD-73/23/EEC




## Wiring & Fixing

Wire the PDS and PDS-OV as in the diagram.

To switch from more than one position simply wire two or more units in parallel to achieve two way and intermediate switching.

The detector should be sited so that the occupants of the room fall inside the detection pattern shown overleaf, at a recommended height of 1.2m to 1.5m. Note that the higher the sensor is installed the shorter the detection range will be.

- ❖ Avoid direct sunlight entering the sensor.
- ❖ Do not site within 1m of forced air heating or ventilation.
- ❖ Do not site within 1m of any lighting.
- ❖ Do not fix to a vibrating surface.




## Installation

**Warning.** This device works at mains potential. Be sure to take care when working with electricity.

1. Make sure the load is connected and in working order.
2. Isolate the mains supply to the circuit at the main consumer unit.
3. Connect the controller via the terminal block. Live supply to the *L* terminal, and the load to the *LIVE OUT* terminal.  
**DO NOT SWITCH THE MAINS SUPPLY ON YET.**
4. With the controller connected set the bottom switch, position 1, to ON to power up the unit. A flashing LED should be visible through the detector lens. If it is then the internal battery is charged and you can proceed to step 6.
5. If not the battery requires charging. Change switch position 1 to OFF, ensure that the mains supply and load are connected, screw the unit to the wall, and switch the mains supply on. The unit should be left for 24 hours to fully charge, after which go back to step 4.
6. Set the LUX level thumbwheel fully clockwise, set the time out period required using the switches according to the chart below. Do this by moving switch positions 2, 3 & 4 only.

**5 Minutes    10 Minutes    15 Minutes    20 Minutes    30 Minutes    40 Minutes    50 Minutes    60 Minutes**



7. Screw the unit to the wall and switch the mains supply back on at the distribution board. The LED behind the detector lens should stop flashing after a few seconds. If it continues to flash there is either no load on the circuit, a problem with the wiring, or the light fitting needs a power factor correction capacitor (see specification overleaf). Fix the problem, turn off switch 1 and start from step 4.

## Installation continued

8. After approximately 5 seconds from power up the load will turn on and for **the first 10 minutes of operating the controller has a fixed time out period of 10 seconds** to aid setting the LUX level. After 10 minutes the time out reverts to the set value.
9. To set the LUX level wait until the level of natural daylight is just enough that lighting is required. Starting with the LUX thumbwheel fully anticlockwise.

Very slowly turn the thumbwheel clockwise until the lights come on. It is important that this is done during the first 10 minutes of power up. If you miss this then move switch 1 to OFF and then back to ON. Note that when the LUX thumbwheel is fully clockwise then the lights will **always** come on with occupancy.

## Installing multiple sensors

### PDS

1. When using multiple sensors to control the same load it is important that each sensor is installed and set up separately.
2. Follow the installation instructions overleaf for the first sensor.
3. Disconnect either or both connections to the sensor (*L* or *LIVE OUT*) but do not change the switch settings.
4. Leaving the first sensor disconnected, connect the second sensor and start the installation procedure from step 1.
5. Leaving both the first and second sensor disconnected, start work on the third sensor etc. until all of the sensors are working.
6. Finally re-connect all of the sensors.

### PDS-OV

1. When using multiple PDS-OV sensors to control the same load it is important that each sensor is turned off before the next sensor is installed.
2. When the each sensor has been installed and is working, simply press the lamp symbol to turn the lights off.
3. After installation has finished, press the lamp symbol on each sensor again to turn the lights back on.

## Product code for ordering:

**PDS** Presence detector

**PDS OV** No Neutral presence detector

Detector manufactured by: 

### IMPORTANT NOTICE!

This device should be installed by a qualified electrician in accordance with the latest edition of AS3000 general electrical wiring regulations.



[www.mysmart.com.au](http://www.mysmart.com.au)

Ph: 1300 697 627

SYDNEY

MELBOURNE

BRISBANE

CANBERRA

PERTH